

Legionella risk assessment

Edward Road Baptist Church
228 Edward Road
Balsall Heath
Birmingham
B12 9LY

2021-10-09

As a church we understand that we owe a duty of care to ensure the safety of those who visit or use our church, hall or grounds. We will ensure that the water supply in our building has a low risk of legionella.

Cold water is directly from a wholesome mains supply (no stored water tanks)

Hot water is fed from instantaneous heaters.

The only outlets are toilets and wash hand basins (i.e. no showers)

There are no air conditioners, humidifiers. long runs of pipe containing warm water or fountains or showers.

There is no water in the system between 20-45degrees C.

There is no rust, sludge, scale or organic matter.

The risk is low and no further action is needed.